LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 928j-(cl-6)

lssue: 02

Sterling Safety Systems Ltd

Unit B12a Holly Farm Business Park Honiley Warwickshire CV8 1NP United Kingdom

is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Heat Detectors HFW-TA-01 HFW-TA-05 (refer to Appendix for details)

Standards

EN 54-5:2000 + A1:2002 EN 54-25:2008

PКЕ

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Malligar.	P Halligan	28 June 2017	25 August 2011	
/	- 5-	20 90110 2017		
Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue	



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit <u>www.redbooklive.com/terms)</u>. To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/check</u>, scan the QR tag or contact us. BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: <u>enquiries@breglobal.com</u> LPCB is a Registered Trademark of the Building Research Establishment Ltd.



LPCB[®]

Appendix to Certificate No: 928j-(cl-6)

Issue: 02

Sterling Safety Systems Ltd

Certified Product	Description	LPCB Ref.No.
HFW-TA-01	 Wireless Heat Detector (WAB100 Base) Notes: Meets the requirements of EN 54-5 for Class A1R The device must be used with the following batteries only: CR123A (3 Vdc) - Main Battery CR2032A (3 Vdc) - Secondary Battery 	928j/01
HFW-TA-05	 Wireless Libra Addressable Class P Heat Detector (WAB100 Base) Notes: Meets the requirements of EN 54-5 for Class A1R and BS The device must be used with the following battery type only: CR123A (3 Vdc) - Primary and Secondary Battery 	928j/02

Bases

WAB100 Wireless Adaptor Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Walligar.	P Halligan	28 June 2017	25 August 2011	
Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue	
AN CERTIFICATION	This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit <u>www.redbooklive.com/terms)</u> . To check the validity of this certificate and appendix please visit			
	www.redbooklive.com/check, scan the QR tag or contact us.			
CERTIFICATION	BRE Global Ltd, Watford, T: +44 (0)333 321 8811	WD25 9XX F: +44 (0)1923 664603 E: <u>enquiries@bregl</u>		
0007	LPCB is a Registered Trad	emark of the Building Research Establishme	ent I to a line and a line an	

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com LPCB is a Registered Trademark of the Building Research Establishment Ltd.