

Certificate of Product Approval

Certificate Number: 928m-(cl-6)

Issue: 03

Sterling Safety Systems Ltd

Unit B12a
Holly Farm Business Park
Honiley
Warwickshire
CV8 1NP
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi Criteria Detector

HFW-MA-01
HFW-MA-05
(refer to Appendix for details)

Standards

EN 54-5:2000 + A1:2002
EN 54-7:2000 + A1:2002 + A2:2006
EN 54-25:2008
CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

28 June 2017

Date of Issue

25 August 2011

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 928m-(cl-6)

Issue: 03

Sterling Safety Systems Ltd

Certified Product	Description	LPCB Ref.No.
HFW-MA-01	Wireless Multi-Criteria Detector (WAB100 Base) Notes: 1. Meets the requirements of EN 54-5 for Class A1R 2. Meets the requirements of EN 54-7 in the normal sensitivity setting 3. The device must be used with the following batteries only - CR123A (3 Vdc) - Main Battery - CR2032A (3 Vdc) - Secondary Battery	928m/01
HFW-MA-05	Wireless Libra Addressable Multicriteria Detector (WAB100 Base) Notes: 1. Meets the requirements of EN 54-5 for class A1R 2. Meets the requirements of EN 54-7 in the normal sensitivity setting Level 1 - High Level 2 - Normal Level 3 - Low 3. The device must be used with the following batteries only - CR123A (3 Vdc) -Primary and Secondary Battery	928m/02

Bases

WAB100 Wireless Adaptor Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

P Halligan
Verifier

28 June 2017
Date of Issue

25 August 2011
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.

