

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2681

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

LW-DMCO-01 Libra Wireless Addressable Multi Criteria Smoke, Heat and CO Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Argus Security Srl
Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy

Argus Security Srl
Via del Canneto 14
Valle delle Noghere
34015 Muggia
Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2000 + A1:2002 - Heat Detectors - Point Detectors
EN 54-7:2000 + A1:2002 + A2:2006 - Smoke Detectors - Point Detectors
EN 54-25:2008 - Components using Radio Links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 21 September 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 21 September 2020

Date of Issue: 21 September 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2681

LW-DMCO-01 Libra Wireless Addressable Multi Criteria Smoke, Heat and CO Detector

Notes:

1. Meets the requirements of EN 54-5 depending on the specific classification setting at classes A1R and BS.
2. Meets the requirements of EN 54-7 at all classification settings.

Classification Settings:

L0 – Harsh smoke profile; smoke profile number 0; heat classification BS.
L1 – Harsh smoke profile; smoke profile number 1; heat classification A1R.
L2 – Harsh smoke profile; smoke profile number 2; heat classification A1R.
L3 – Harsh smoke profile; smoke profile number 3; heat classification A1R.
N0 – Normal smoke profile; smoke profile number 0; heat classification A1R.
N1 – Normal smoke profile; smoke profile number 1; heat classification A1R.
N2 – Normal smoke profile; smoke profile number 2; heat classification A1R.
N3 – Normal smoke profile; smoke profile number 3; heat classification A1R.
H0 – Clean smoke profile; smoke profile number 0; heat classification A1R.
H1 – Clean smoke profile; smoke profile number 1; heat classification A1R.
H2 – Clean smoke profile; smoke profile number 2; heat classification A1R.
H3 – Clean smoke profile; smoke profile number 3; heat classification A1R.

Base

WAB100 Base



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 21 September 2020

Date of issue: 21 September 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie