

## BRE Global

### UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0617

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

### HFV-MA-05 Wireless Libra Addressable Multi-Criteria Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

**Hyfire Wireless Fire Solutions Limited**  
Unit B12a, Holly Farm Business Park  
Honiley  
Warwickshire  
CV8 1NP  
United Kingdom

**Argus Security S.r.l**  
Via del Canneto 14  
Valle delle Noghere  
34015 Muggia  
Trieste  
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-5:2017 +A1: 2018 - Heat detectors – Point heat detectors**  
**EN 54-7:2018 - Smoke detectors – Point smoke detectors**  
**EN 54-25:2008 Components Using Radio Links**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 09 November 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 09 November 2021

Issue Date: 05 September 2022

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

**BRE Global**

**UK Approved Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0617**

**HFW-MA-05 Wireless Libra Addressable Multi-Criteria Detector**

**Notes:**

1. Meets the requirements of EN 54-5 for Category A1R
2. Meets the requirements of EN 54-7 at the following sensitivity settings:  
Level 1 - High  
Level 2 - Normal  
Level 3 - Low
3. The device must be used with the following battery type only:  
CR123A (3 Vdc) - Primary and Secondary Battery

**Base:**

WAB100 – Wireless Adaptor Base



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 09 November 2021

Issue Date: 05 September 2022

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)