



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0051-CPR-2559

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation, or CPR), this Certificate applies to the construction product

Product: **SOUNDER USING RADIO LINKS**
Model: **TAU-MWSO-01 + HFC-WSR-03**
TAU-MWSO-01 + HFC-WSW-03
Trademark: **HYFIRE**
Other information: **see ANNEX**

Produced by:
HYFIRE WIRELESS FIRE SOLUTIONS LTD
Unit B12a, Holly Farm Business Park, Honiley Warwickshire CV8 1NP (UK)

In the manufacturing plant:
PI.Q0009R

This Certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006
EN 54-25:2008 + AC:2012

Under system **1** are applied and that **the product fulfills all the prescribed requirements set out above**

ISSUED ON 22/09/2022

REVISION 1

B.U. PRODUCT CONFORMITY ASSESSMENT
CPR TECHNICAL DIRECTOR

This certificate cancels and replaces the certificate having the same number and issued on 2021-11-11 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the products, and the manufacturing conditions in the plant are not modified significantly.

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011. IMQ S.p.A. Identification Number is: **0051**. This certificate is subjected to the Regulation of Assessment and Verification of Constancy of Performance of the Construction Products as Notified Body, according to Regulation (EU) no. 305/2011 and Legislative Decree n.106/ 2017 (REG. ON / CPR)

ANNEX

0051 – CPR – 2559

Configuration

The sounder alarm device model TAU-MWSO-01 + HFC-WSR-03 and TAU-MWSO-01 + HFC-WSW-03 (White) consists of a plastic enclosure [dimensions: 130 (d) x 90 (h) mm] with IP33C degree of protection, divided into:

- Wireless module model TAU-MWSO-01, containing:
 - No. 1 Main board (PCB code B40-ISWSM-0002);
 - No. 2 Battery allocable (CR123A Lithium, 3 V – 1.25Ah);
- Sounder and visual alarm device model HFC-WSR-03, containing:
 - No. 1 Main board (PCB code B20-CWS1X-1002);
 - No. 1 Piezoelectric buzzer;

Technical Characteristics

Tone patterns in compliance with EN 54-3:

- Warble Tone: 800 Hz for 500 ms then 1000 Hz for 500 ms;
- Continuous tone: 970 Hz continuous;
- Slow Whoop (Dutch): 500-1200 Hz for 3500 ms, then off for 500 ms;
- German DIN tone: 1200-500 Hz swept every 1000 ms (1 Hz);
- Destination for use: Type B (for external);
- Operating frequency band: 868 MHz ; 916 MHz;
- Hardware identification of the microcontroller (U5) used on the main board (PCB code B40-ISWSM-0002):
 - STMicroelectronics, STM32L051R8;
- Firmware identification of the microcontroller (U5) used on the main board (PCB code B40-ISWSM-0002):
 - 0_1_12, using the 868 MHz frequency band;
 - 0_1_13, using the 916 MHz frequency band.

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011. IMQ S.p.A. Identification Number is: **0051**. This certificate is subjected to the Regulation of Assessment and Verification of Constancy of Performance of the Construction Products as Notified Body, according to Regulation (EU) no. 305/2011 and Legislative Decree n.106/ 2017 (REG. ON / CPR)