# Certificate No.: 8504-UKCA-CPR-UKCSP10154



### **C**ERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

TAU-MWSO-01+HFC-SBR-23-03
---------------------------

The product fulfils the essential characteristic:

	See Annex 1			
Intended use	: Applications r	lated to aut	omatic fire al	arm systems
Placed on the	e market under the name or trade mark c	f:		
	Hyfire Wireles	Fire Solutio	ns Ltd	
	Unit B12a Holl	/ Farm Busir	ess Park	
	Honiley, Warw	ickshire, CVរ	B1NP	
	United Kingdo	n		
and produced	d in the manufacturing plant:			
	UKCPA10005			
This attests t	hat all provisions concerning the perform	ance describ	ed in Annex 2	ZA of the standard(s)

EN 54-3:2001+A1:2002+A2:2006	:	Fire detection and fire alarm systems — Part 3: Fire alarm devices — Sounders	
EN 54-23:2010	:	Fire detection and fire alarm systems — Part 23: Fire alarm devices — Visual alarm devices	
EN 54-25:2008+AC:2012	:	Fire detection and fire alarm systems — Part 25: Components using radio links	

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-08-10 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2022-08-10.

Merete Poulsen Responsible for evaluation

Steen Nilsson Responsible for certification decision



# Certificate No.: 8504-UKCA-CPR-UKCSP10154



#### Annex 1

#### EXTENT

#### Product description:

TAU-MWSO-01+HFC-SBR-23-03 sounder and visual alarm device using radio links

#### **Configuration:**

The sounder and visual alarm device model TAU-MWSO-01 + HFC-SBR-23-03 consists of a plastic enclosure (dimensions: 130 (d) x 90 (h) mm) with IP33C degree of protection which contains a:

- Wireless module model TAU-MWSO-01, containing:
  - No. 1 Main board (PCB code B40-ISWSM-0002)
  - No. 2 Battery allocable (CR123A Lithium, 3 V 1.25Ah)
- Sounder and visual alarm device model HFC-SBR-23-03, containing
  - No. 1 Main board (PCB code B20-CWS1X-1002)
  - No. 1 Piezoelectric buzzer

#### Technical Characteristics:

Tone patterns in compliance with EN 54-3:

- Warble Tone: 800 Hz for 500 ms then 1000 Hz for 500 ms
- Continuous tone: 970 Hz continuous
- Slow Whoop (Dutch): 500-1200 Hz for 3500 ms, then off for 500 ms
- German DIN tone: 1200-500Hz swept every 1000 ms (1Hz)

Coverage characteristics: W2.5-7

Flash rate: 0.5 Hz

Destination for use: Type B (for external)

Operating frequency band: 868 MHz ; 916 MHz

Hardware identification of the microcontroller (U5) used on the main board (PCB code B40-ISWSM-0002):

STMicroelectronics, STM32L051R8

Firmware identification of the microcontroller (U5) used on the main board (PCB code B40-ISWSM-0002):

- 0\_1\_12, using the 868 MHz frequency band
- 0\_1\_13, using the 916 MHz frequency band

#### List of optional functions with requirements (EN 54-23):

4.3.7 Synchronization

Performance

Essential characteristics	Clauses in EN 54-3:2001+A1:2002+A2:20	006 Performance
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	Pass
Operational reliability	4.4, 4.5, 4.6, 5.4	Pass
Durability of operational reliability and response delay; temperature resistance	5.5, 5.6, 5.7, 5.8, 5.9	Pass
Durability of operational reliability; humidity resistance	5.8, 5.9, 5.10	Pass
Durability of operational reliability; corrosion resistance	5.11	Pass
Durability of operational reliability; vibration resistance	5.12 to 5.15	Pass
Durability of operational reliability; electrical stability	5.16	Pass
Durability of operational reliability; resistance to ingress	5.17	Pass

#### DBI Certification-UK Ltd.

Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk



# Certificate No.: 8504-UKCA-CPR-UKCSP10154



Essential characteristics		Clauses in	n EN 54-23	3:2010	Level(s) or c	lass(es)	Notes
Operational reliability:							
Duration of operation			4.2.1				Pass
Flammability of materials			4.2.3				Pass
Enclosure protection			4.2.4				Pass
Access			4.2.5				Pass
Manufacturer's adjustments			4.2.6				Pass
Requirements for software controlled devices			4.2.8				Pass
			4.2.0				F d55
Performance parameters under fire cor	altion:		1 2 1				Dava
Coverage volume			4.3.1				Pass
Variation of light output			4.3.2				Pass
Minimum and maximum light intens	ity		4.3.3				Pass
Light colour			4.3.4				Red/White
Light temporal pattern and frequence	y of flashing		4.3.5				Pass/0.5 H
Marking and data			4.3.6				Pass
Synchronization (option with require	ements)		4.3.7				Pass
Durability:							
Temperature resistance:					None	5	
Dry heat (operational)			4.4.1.1				Pass
Dry heat (endurance)			4.4.1.2				Pass
Cold (operational)			4.4.1.3				Pass
Humidity resistance:							1 435
Damp heat, cyclic (operational)			4.4.2.1				Pass
Damp heat, steady state (endurance	<b>`</b>		4.4.2.2				
						Pass	
Damp heat, cyclic (endurance)			4.4.2.3				Pass
Shock and vibration resistance:							
Shock (operational)			4.4.3.1				Pass
Impact (operational)			4.4.3.2				Pass
Vibration (operational)		4.4.3.3				Pass	
Vibration (endurance)			4.4.3.4				Pass
Corrosion resistance:							
SO <sub>2</sub> corrosion (endurance)			4.4.4				Pass
Electrical stability:							
EMC, immunity (operational)			4.4.5				Pass
Essential characteristics	Clau	uses in EN 5			12	Per	formance
Performance parameters under fire conditions		4.1, 4.2	.2, 5.2, 8.3	3.7			Pass
Response delay (response time to fire)		8.2	.3, 8.2.6	-			Pass
Operational reliability	4.2.1, 4.2.3			8.2.2, 8	.2.4, 8.2.5,		Pass
,	8.2.7, 8.2.8, 8						
Durability of operational reliability	,- ,-		.3.10, 8.3.				Pass
and response delay; temperature		0.0.0, 0		_			
resistance							
Durability of operational reliability;		0 2 1 6 0	2 17 +0 0	2 10			Dace
		0.3.16, 8.	3.17 to 8.3	5.13			Pass
vibration resistance							_
Durability of operational reliability;		8.3.12,8	3.3.13, 8.3	.14			Pass
humidity resistance							
Durability of operational reliability;		8	3.3.15				Pass
corrosion resistance							
Description of a second second sector bits in the		ç	3.3.20				Pass
Durability of operational reliability;		L L L L L L L L L L L L L L L L L L L	5.5.20				1 4 5 5

**DBI Certification-UK Ltd.** Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk





### Annex 2

**TEST DOCUMENTATION** Test documentation can be found in case no. UKCSP10085-001.

#### **TECHNICAL BASIS**

TECHNICAL BASIS		
File Number	Title	Date
BOM-CWS1X-1002	CONVENTIONAL WALL SOUNDER BEACON (CWS100-AV) & WHITE VERSION CWS100-AV(W) - Bill of Material	2022-03-25, Rev. Q
BOM-TWMWS-0002	TAURUS WIRELESS WALL SOUNDER OUTPUT MODULE (TW-MWSO-01) - 868 / 916 MHz VARIANTS - Bill of Mater	ial 2021-12-27, Rev. N

**DBI Certification-UK Ltd.** Unit 1 & 2, Northcot Park, Station Road, Blockley, Gloucestershire GL56 9LH E-mail: info@dbicertification.co.uk · www.dbicertification.co.uk

