# Certificate No.: 8504-UKCA-CPR-UKCSP10159



## **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification-UK, approved body No. 8504.

In compliance with UK STATUTORY INSTRUMENT 2020 No. 1359 Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the construction product

### TAU-TRM-01, TAU-TRM-01-BL

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Hyfire Wireless Fire Solutions Ltd Unit B12a Holly Farm Business Park Honiley, Warwickshire, CV81NP United Kingdom

and produced in the manufacturing plant:

**UKCPA10005** 

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-17:2005 : Fire detection and fire alarm systems — Part 17: Short circuit isolators
EN 54-18:2005 : Fire detection and fire alarm systems — Part 18: Input/output devices

EN 54-25:2008+AC:2012 : Fire detection and fire alarm systems — Part 25: Components using radio links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

# CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-08-10 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: 2022-08-10.

Merete Poulsen
Responsible for evaluation

Steen Nilsson

Responsible for certification decision



Version 2022-02-08 Page **1** of **3** 

# Certificate No.: 8504-UKCA-CPR-UKCSP10159



#### Annex 1

#### **EXTENT**

#### **Product description:**

TAU-TRM-01 Input/Output Device using Radio Links with Short-Circuit Isolator Integrated TAU-TRM-01-BL Input/Output Device using Radio Links with Short-Circuit Isolator Integrated

#### Configuration

The input/output device model TAU-TRM-01 and TAU-TRM-01-BL consists of a plastic enclosure (dimensions: 235 x 160 x 65 mm) with IP30 degree of protection, containing:

- No. 1 Main board (PCB code B40-TWMTI-0003)
- No. 1 Display board (PCB code B20-CWEX2-2002)
- No. 1 SX antenna board (PCB code B40-CWEX2-3002)
- No. 1 DX antenna board (PCB code B40-CWEX2-4001)

#### **Technical Characteristics**

Operating frequency band: 868 MHz; 916 MHz

Hardware identification of the microcontroller (U6 and U15) used on the main board:

- STMicroelectronics, STM32L471VG (U6)
- STMicroelectronics, STM32L151RC (U15)

Firmware identification of the microcontroller (U6 and U15) used on the main board:

- 0\_9\_2f (U6); 0\_6\_2a (U15), using the 868 MHz frequency band
- 0\_9\_2f (U6); 0\_6\_3 (U15), using the 916 MHz frequency band

#### **Performance**

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 <sup>1)</sup>	Pass
Operational reliability	4	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	Pass

1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices

#### **DBI Certification-UK Ltd.**

 $\label{localization} \mbox{Unit 1\& 2, Northcot Park, Station Road, Blockley, Gloucestershire $\mbox{ GL56 9LH E-mail: info@dbicertification.co.uk} \cdot \mbox{www.dbicertification.co.uk}$ 



No. 2333

# Certificate No.: 8504-UKCA-CPR-UKCSP10159



Essential characteristics	Clauses in EN 54-18:2005	Performance
Response delay (response time)	5.2 <sup>1)</sup>	Pass
Performance under fire conditions	5.1.4	Pass
Operational reliability	5.1.4	Pass
Durability of operational reliability; temperature resistance	5.3, 5.4	Pass
Durability of operational reliability; vibration resistance	5.8 to 5.11	Pass
Durability of operational reliability; numidity resistance	5.5, 5.6	Pass
Ourability of operational reliability; corrosion resistance	5.7	Pass
Ourability of operational reliability;	5.2, 5.12	Pass

<sup>1)</sup> Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard

Essential characteristics	Clauses in EN 54-25:2008+AC:2012	Performance
Performance parameters under fire conditions	4.1, 4.2.2, 5.2, 8.3.7	Pass
Response delay (response time to fire)	8.2.3, 8.2.6	Pass
Operational reliability	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	Pass
Durability of operational reliability and response delay; temperature resistance	8.3.9, 8.3.10, 8.3.11	Pass
Durability of operational reliability; vibration resistance	8.3.16, 8.3.17 to 8.3.19	Pass
Durability of operational reliability; humidity resistance	8.3.12, 8.3.13, 8.3.14	Pass
Durability of operational reliability; corrosion resistance	8.3.15	Pass
Durability of operational reliability; electrical stability	8.3.20	Pass

### Annex 2

## TEST DOCUMENTATION

Test documentation can be found in case no. UKCSP10090.

## Annex 3

## **TECHNICAL BASIS**

File Number	Title	Date
BOM-TWMTI-0003	TAURUS WIRELESS VEGA TRANSLATOR (TW-MTI-01) - 868 / 916 MHz VARIANTS - Bill of Material	2022-03-25, Rev. R

## DBI Certification-UK Ltd.



Version 2022-02-08 Page **3** of **3**