

N° DOC-HY-HYGO-01EU

## UE – DICHIARAZIONE di CONFORMITÀ EU - DECLARATION of CONFORMITY

Fabbricante / Manufacturer	Hyfire Wireless Fire Solutions Ltd.
Indirizzo / Address	Unit 12A, Holly Farm Business Park Honiley, Warwickshire, CV8 1NP, UK

Il produttore sopra identificato dichiara sotto la propria responsabilità che il prodotto oggetto di questa dichiarazione:

The manufacturer identified above herewith declares under its responsibility that the products covered by this declaration:

Control and Indicating Equipment	
Famiglia/Family	HY-GO Series Fire & Control Indicating Panels & Peripherals
Modello/Product Code	Descrizione/Description
<b>HY-GO/66</b>	Fire detection and fire alarm single loop panel, configurable up to 66 analogue addressable detector devices
<b>HY-GO/240</b>	Fire detection and fire alarm single loop panel, configurable up to 66 analogue addressable detector devices
<b>Common optional modules for all HY-GO CIE</b> (Tested as part of the control and indicating system listed in CPR report)	
<b>GOP-001</b>	Peripheral BUS adaptor

Campo di utilizzo / Use for:

**Sistemi di rilevazione e allarme anticendio / Fire detection and alarm system**

Risulta in conformità a quanto previsto dalla seguente direttiva comunitaria  
(comprese tutte le modifiche applicabili)

Is in conformity with the provisions of the following EC directives  
(including all applicable amendments)

Rif./Reference	: And that the technical / standards specifications indicated below have been applied:
2014/30/EU Electromagnetic Compatibility (EMC) Directive	EN 61000-3-2:2014
	EN 61000-3-3:2013
	EN 50130-4:2011 + A1:2014
	EN 55032:2015
2014/35/EU Low Voltage (LVD) Directive	EN 62368-1:2014 +A11:2017
2011/65/EU Restriction of Hazardous Substances (RoHS) Directive	EN IEC 63000:2018

Il Fabribbricante ha creato un Fascicolo Tecnico, riferimento/numero/directory:  
The Manufacturer has created the Technical ConstructionFile, reference/number/directory  
\\SSS-dc01.sterling.local\Sterling Server\Conformance\Conformance - Product

Il marchio CE è stato apposto per la prima volta:2023  
The CE mark was first applied in 2023



La presente dichiarazione è resa in nome e per conto del direttore di Hyfire Wireless Fire Solutions Limited, il signor Tom Crane, che è stato designato come persona responsabile ai fini delle normative

This declaration is made for and on behalf of Hyfire Wireless Fire Solutions Limited Director, Mr. Tom Crane who has been designated as the responsible person for the purpose of the regulations.

Signature 

Tom Crane – Business Unit Director – Hyfire Wireless Fire Solutions Ltd.  
Honiley UK, 20 September 2023